DRIVE-THRU UNIT 3



Ambient (Unheated) Air Curtain Data Sheet

For Opening Heights up the 3'

STANDARD CONSTRUCTION

- 7" high x 7 3/4" deep
- One speed motor(s)
- Factory installed on/off switch
- · Silver powder coated extruded aluminum exterior cabinet
- Factory installed "Mount Anywhere" bracket system
- 6' plug-in type power cord
- Filter (washable)

1 Year Limited Warranty







MODEL	Nozzle Width (in)	Max Vel. at Nozzle (fpm)	Avg. Outlet Vel. (fpm)	Air Volume (cfm)	Outlet Vel. Uniformity	Power Rating (kW)	Motor(s) @ hp	Net Wt. (Ibs)
DTU03-1018A	16.50	2,800	1,047	135	76%	0.06	1 @ 1/2	11
DTU03-2026A	24.50	2,800	1,045	200	79%	0.10	1 @ 1/2, 1 @ 1/20	16

NOTE: Operation at 50 Hz will generate approximately a 17% reduction in air performance. See sheet EP-010 for amp draws/total load requirements.

MODEL NUMBER CONFIGURATION DTU03-1 018 A A Series # of Motors Opening Width Heat Voltage DTU03 1, 2 18" - 26" A= Ambient *A=120/1/60

*A=120/1/60 *Suitable for 50hz

VELOCITY PROFILE: Model DTU03-1018A			
Distance from Nozzle (in)	1	36	
Core Velocity (fpm)	1622	783	

Sound level measured 10' (3m) from the unit in free field: 1 & 2 motor(s): 51.5 dBA & 52.0 dBA


Berner reserves the right to alter specifications without prior notice.






		120/1/60 (voltage code A) MOTOR AMP DRAW = N/A		
MODEL	# CKTS	AMPS PER CIRCUIT	BREAKER RATING PER CIRCUIT	
DTU03-1018A	1	1.6	15	
DTU03-2026A	1	2.2	15	


Berner reserves the right to alter specifications without prior notice.



FRONT VIEW




BOTTOM VIEW



MODEL 🙆	NOZZLE WIDTH	UNIT WIDTH "B"	MOUNTING WIDTH	
DTU03-1018AA	16.500 [41.91]	20.125 [51.12]	17.250 [43.82]	
DTU03-2026AA	24.500 [62.23]	28.125 [71.43]	25.250 [64.14]	

DTU03 AMBIENT SYSTEM



NOTES:

AIR CURTAIN MUST BE INSTALLED SO AIR STREAM IS NOT OBSTRUCTED WHEN DEFLECTED 20° TO EITHER SIDE OF G.

ELECTRICAL CONNECTIONS TO BE FLEXIBLE.

AIR FLOW

FIELD VERIFY DIMENSIONS.

 $\stackrel{ riangle}{4}$ anchors to supporting structure by others.

ADEQUACY OF SUPPORTING STRUCTURE IS TO BE VERIFIED BY A PROFESSIONAL STRUCTURAL ENGINEER.

LETTER "AA" IN MODEL NUMBER DESIGNATES 120V AMBIENT UNIT.

DIMENSIONS IN INCHES [CENTIMETERS].

PROJECT		
LOCATION		
ARCHITECT		
ENGINEER		
DWG. NO.	DTU03-A	TITLE: BERNER
DATE	21MAY14	MODEL DTU03 AIR CURTAIN
BY	S. Beil	AMBIENT SYSTEM
REPLACES	-	BERNER INTERNATIONAL CORP.
BY	-	NEW CASTLE,PA.
PDF NO.		