

**T&S BRASS AND BRONZE WORKS, INC.**

2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690

PHONE 800-476-4103

FAX 864-834-3518



REG.#A2601  
ISO #9002

Model No.


B-0199-21-VRF

Item No.:

Job Name:

Architect/Engineer Approval:

Notes:



**NOTES:**

1. PROVIDES A SPLASH FREE CLEAR (NON AERATED) STREAM
2. SCREENLESS CONSTRUCTION PREVENTS LIME BUILD UP.
3. RECOMMENDED FOR USE IN MEDICAL FACILITIES TO PREVENT AIRBORNE BACTERIA FROM ENTERING THE WATER STREAM.
4. PRESSURE COMPENSATING FOR CONSTANT 2.2 GPM FLOW RATE FROM 20 TO 80 PSI.
5. APPROVALS: NSF/ANSI 61, ASME A112.18.1M, CSA B125, AND VETERAN HEALTH ADMINISTRATION (VHA) DIRECTIVE 97-027.

Product Description:

VANDAL RESISTANT LAMINAR CONTROL DEVICE  
WITH FEMALE AERATOR THREAD

Drawn:

BHR

Approved

JHB

Checked

DHL

Scale:

1:1

Date:

07/11/07