Drawn:

DMH

Checked:

T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

Model No.

EC-3132-VF05

Item No.

NSF 61 - Section 9 NSF 372 (Low Lead Content)

1:6

Sheet: 1 of 2

ANSI A117.1 (ADA)

Scale:

UL 1951

04/22/14

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

L	ChekPoint"	This Spa	ce for Architect/Engineer Ap	proval
<u>G</u> .		lob Name		
ADA Compliant Cold	1	Model Specifie	ed	_Quantity
Ø2 1/2"		Customer/Who	olesaler	
[64mm]		Contractor		
Hot		Architect/Engi	neer	
Cast Spout w/ 2.2 GPM [8.3 L/min] Vandal Resistant Aerator (Optional 0.5 GPM VR Non-Aerated Spray Device Included) Internal Above Deck Electronics w/ Flow Control Setting Switches. Powered w/ 6 VDC Lithium Battery.	Temperature Mixin w/ Color Coded Ind (Optional Plug Incl Replace Handle W Temperature is Pre	g Handle dex uded to fren eset) 1 [38 Max Thick of Supply wivel Ends ers ession	5 1/2" [140mm] 5/8" 9mm] 1/2" kimum ckness	7 11/16" [195mm]
Rough-In Requirement: Ø1 1/4" [32mm] Mounting Hole Ø3/16" [5mm] Anti-Rotation Pin Hole (Optional	,	แแษเจ		
Product Specifications:			Product Compliance:	
Chrome Plated Brass Above Deck Electronics Faucet, Single Hole Deck Mount, Cast Spout w/ VR Aerator, Optional 0.5 GPM VR			ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9	

Spray Device, Point-of-Use Temp. Control, Battery or AC Adapter Powered, Stainless Steel Flexible Supply Lines & 3/8" Comp. Inlets

Approved:

Date:

GEF




T&S BRASS AND BRONZE WORKS, INC.


2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

EC-3132-VF05

Item No.


Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com







A maximum of (8) ChekPoint faucets can be powered by EC-HARDWIRE ChekPoint Hardwire AC Transformer when connected using EC-ADEWIRE cables. (Both sold separately)









Optional Plug Replaces Lever Handle When Pre-setting Temperature (Installs from Inside of Body) 015425-45 018543-45 VR Aerator Key Torx T-20 VR L-Key

Flow Control Switches are Located Behind the Sensor. Remove Battery to Access Switches.

- * Switches are set to DEFAULT position:
 - Auto Time Out = 15 seconds
 - Shut Off Delay = 1 second
 - Auto Flush = ÓFF
- * Available Water Flow Control Selections:
 - Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min
 - Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec
 - Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF

Product Specifications:

Chrome Plated Brass Above Deck Electronics Faucet, Single Hole Deck Mount, Cast Spout w/ VR Aerator, Optional 0.5 GPM VR Spray Device, Point-of-Use Temp. Control, Battery or AC Adapter Powered, Stainless Steel Flexible Supply Lines & 3/8" Comp. Inlets

6

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951

Drawn: DMH Checked: GEF Approved: JHB Date: 04/22/14 Scale: NTS Sheet: 2 of 2